

| |
|---|
| TECHNICAL SPECIFICATION OF MITSUBISHI BASIC DIESEL GENERATOR SET |
|---|

This specification covers the indoor use MITSUBISHI diesel engine generator set and attached equipment.

| | MGS Model | MGS0900B | | | | | |
|----------------------------------|--|--|------------|-------------|---------------|---------------|--------------|
| | Code Name | 5S-H6J | 5P-H6J | 6S-H6J | 6P-H6J | 6S-H6H | 6P-H6H |
| Generator Set | Frequency (Hz) | 50 | | | 60 | | |
| | Voltage ¹ (V) | 380 | | | 380 | | 480 |
| | Duty | Stand-by | Prime | Stand-by | Prime | Stand-by | Prime |
| | Rated Output ¹ (kVA) (kW) | 1000 800 | 885 708 | 1075 860 | 981.25 785 | 1087.5 870 | 987.5 790 |
| Engine | Model | S12A2-PTA2-S | | | | | |
| | Speed (min ⁻¹) | 1500 | | | 1800 | | |
| | Output ² (kWm) | 850 | 771 | 920 | 834 | 920 | 834 |
| | Fuel Consumption ^{3,5} (liter/hr) | 163 | 147 | 184 | 168 | 174 | 157 |
| | Lub.Oil Consumption ⁴ (liter/hr) | 0.77 | 0.68 | 0.83 | 0.76 | 0.83 | 0.76 |
| | Cooling System | Closed looped circuit by integral radiator | | | | | |
| Generator | Model | MG-HC6J | | MG-HC6J | | MG-HC6H | |
| | Phase & Wire | 3Phase 4 Wire | | | | | |
| | Power Factor | 0.8 lagging | | | | | |
| D/G Set Dimension & Weight | Length (mm) | 4060 | | 4060 | | 4060 | |
| | Width (mm) | 1715 | | 1715 | | 1715 | |
| | Height (mm) | 2100 | | 2100 | | 2100 | |
| | Weight (kg) | 6800 | | 6800 | | 6600 | |

Note 1 For actual voltage and output, refer to the "Scope of supply" sheet

Note 2 Output at 40 deg C , 1000m ASL with Fan

Note 3 Fuel Consumption at 75% Load

Note 4 Lub. Oil Consumption at 100% Load

Note 5 Fuel Consumption may differ subject to site condition and specification of fuel.
Not guaranteed value

RATING DEFINITION

| Duty | Stand-by | Prime |
|--|--|--|
| Over Load | Not Available | 10% |
| Yearly Average Load Factor | Less than 60% | Less than 60% |
| Yearly Operating Hours | Less than 100 hours | Less than 500 hours |
| Allowable Average Load Factor For 24 Hours | 1) 80% of Rated Power 2) 100% of Rated Power is available intermittently for less than 12 hours per year. | 1) 90% of Rated Power 2) More than 100% of Rated Power is available intermittently for less than 1 hour per 12 hours. (Max. 12 hours per year) |

1. BASIC CONDITIONS

1.1 MEASUREMENT

Unit of measurement, weight, and capacity concerning all of the equipment supplied by us, SI unit and English letter are used.

1.2 SHOP TEST

Diesel generator test shall be carried out on the following items at the manufacturer's shop.

(1) Starting and stopping test.

(2) Load test

| | 0% Load | 25% Load | 50% Load | 75% Load | 100% Load | 110% Load |
|-----------------|------------|-------------|-------------|-------------|--------------|--------------|
| Stand-by Rating | 5 min | 10 min | 10 min | 10 min | 20 min | ----- |
| Prime Rating | 5 min | 10 min | 10 min | 10 min | 20 min | 10 min |

(3) Governor test.

(4) Insulation and alarm test.

Generator and switchboard test shall be carried out at generator manufacturer's shop. After the test, the test record shall be submitted.

1.3 Applicable standard

To be in accordance with JIS, JEC, JEM, IEC and manufacturer's standards unless otherwise specified

- a) J.I.S. : Japanese Industrial Standards
- b) J.E.C. : Standard of the Japanese Electrotechnical Committee
- c) J.E.M. : The standard of Japanese Electrical Manufacturers Association
- d) I.E.C. : International Electrotechnical Commission
- e) I.S.O. : International Organization for Standardization

1.4 GUARANTEE

The guarantee shall be valid for the period of twelve (12) calendar months after completion of commissioning test at site or for the period of eighteen (18) calendar months after B/L date, whichever comes earlier. The guarantee shall cover against manufacturer defect, bad materials and workmanship only, and shall not be applicable to damage sustained through mishandling of the equipment and force majeure. The guarantee shall not be liable for any consequential or resultant loss or damage howsoever occurring. The guarantee shall be subject to the proper maintenance of machinery and equipment according to the maintenance schedule to be submitted separately.

1.5 PAINTING

Mitsubishi standard (Dark Blue) Munsell 6.0PB 4.4/5.2

1.6 ENVIRONMENT ETC.

Generator sets are designed under the following operating conditions

- a) Relative humidity : Max. 85%
- b) Ambient temperature : 40deg.C
- c) Altitude above sea level : Below 1000 meters

2. DIESEL ENGINE

2.1 Particulars of diesel engine

| | |
|--|---|
| Engine model | S12A2-PTA2-S 4 cycle, direct injection, turbocharged, with air cooler |
| No. of cylinder | 12-Vee |
| Bore / stroke (mm) | 150 / 160 |
| Total displacement | 33.9 liter |
| Compression Ratio | 15.3 : 1 |
| Frequency regulation (as generator set) | Temporary 12% (100% throw off) 10% (50% throw in) Permanent5% Steady state Frequency band..... $\pm 0.25\%$ Other performance with ISO 8528 / V Class G2 governing |
| Governor | Electrical type |
| Fuel oil | ASTM D975-1992 diesel fuel oil No.2-D |
| Fuel injection pump | Bosch type |
| Fuel injection nozzle | Hole nozzle type |
| Fuel feed pump | Forced feeding by piston type pump |
| Fuel filter | Paper element type |
| Lubricating oil | API classification Service, "CD" class. SAE No.30 |
| Lubricating system | Forced lubricating by gear pump wet sump system |
| Lub. oil capacity | 120 liter |
| Lub. oil filter | Full flow paper element type |
| Lub. oil cooler | Water cooled corrugated type |
| Water pump | Centrifugal type driven by engine |
| Turbocharger | Exhaust gas turbine |
| Air cleaner | Turbo filter type |
| Starting system | Electric starting Starting motor capacity (DC24V) : 7.5kW \times 2 |
| Stopping system | Energize to run type solenoid on the fuel linkage |

2.2 Engine Instrument

Engine instruments shall be installed in the generator panel.

Engine status are showed by graphical icon and digital indicator on LCD display of the generator panel.

3. AC GENERATOR

The brushless AC Generator coupled with the diesel engine and installed onto a common bed.

The AC Generator provided the following characteristics.

3.1 Particulars of the AC Generator

(1) Standard specification

| | |
|-------------|--|
| Type | : Brushless, self excited, self ventilating and rotating field |
| Protection | : IP23 |
| No. of pole | : 4 pole |
| Insulation | : Class "H" |
| Exciter | : Brushless |
| Bearing | : Single ball bearing |

3.2 Characteristics (AC Generator)

(1) Steady state voltage regulation

Voltage Regulation will be $\pm 0.5\%$ when the load varies between no load and full load at power factors between 0.8 and 1.0 over a prime mover speed range of 4%.

(2) Transient Response

The Instantaneous Voltage Regulation will be within 25% and recoverable to within 3% of the final steady-state voltage in not more than 1sec., when full load at a power factor of 0.4 or less is suddenly applied to the AC Generator running at no load and rated frequency. However engine response may influence on recovery time.

(3) Voltage wave form

The wave form deviation of phase to phase voltage, as checked at the AC Generator terminals, is not greater than 5% at no-load rated voltage.

(4) Unbalanced loading

An acceptable value of negative phase sequence current is approximately 8% of rated current. Up to 25% load imbalance can be tolerated on a continuous basis.

(5) Temperature rise limits

The main windings of the AC Generator are designed for operation to Class H temperature rise limits.

(6) Insulation strength

The dielectric strength of the winding insulation system is checked during manufacture by conducting a High Voltage withstand test.

Main Stator winding : AC 2000V

Main Rotor winding : AC 1500V

(7) Overspeed

The AC Generator is capable of withstanding overspeeds to 125% of the rated speed for two minutes under no load.

(8) Voltage adjustment is typically $\pm 6\%$ using a remotely connected trimmer.

(9) Terminal box

The large fabricated sheet steel terminal box mounted on the AC Generator accommodates load output terminals and access cover.

4.GENERATOR CONTROL (MGS7310GCP)

4.1 General

Automatic start engine management and instrumentation system module in fabricated cubicle is installed on individual bracket with anti-vibration isolator.

4.2 Instruments and control accessories

Instruments are graphical icon on LCD display

- a) Generator running indicator
- b) Voltage adjuster
- c) Frequency adjuster
- d) Emergency stop switch
- e) Selector switch (STOP / RESET , ACTIVE , PANEL LOCK)
- f) Manual start button
- g) Manual stop button
- h) Common alarm indicator
- i) Transfer to generator button (manual mode only)
- j) Transfer to main button (manual mode only)
- k) Mute alarm button
- l) Manual Mode button
- m) Auto Mode button
- n) Menu navigation buttons
- o) Alarm indication on LCD (see 4.3)
- p) Status indicator (see 4.5)

q) Value display on LCD

- 1) Frequency / RPM
- 2) AC voltage phase
- 3) AC voltage phase-phase
- 4) AC Line Current
- 5) Oil pressure
- 6) Coolant temperature
- 7) Oil temperature ^λ
- 8) Engine hours run
- 9) DC battery voltage
- 10) Generator frequency
- 11) Generator load / kW
- 12) Generator load / kVA
- 13) Power factor / pf
- 14) Generator load / kVAr
- 15) Generator load / kWh, kVAh, kVarh
- 16) Generator phase sequence
- 17) Generator Nominal
- 18) Exhaust gas temperature ※^λ
- 19) Winding temperature (U,V,W) ※^λ
- 20) Bearing temperature ※^λ

※ These values shall be displayed on the alarm box adjacent to MGS7310GCP

λ Optional item upon request

4.3 Fault operation

Fault operations shall be provided as follows;

| Item | Value | Eng. stop | Light Fault | Heavy Fault | Indication |
|---|---------|-----------|-------------|-------------|------------|
| Charge Alternator Failure | 19.2V | — | × | — | × |
| Battery Under Voltage | 18V | — | × | — | × |
| Battery Over Voltage | 31.2V | — | × | — | × |
| Fail to Stop | 30sec | — | × | — | × |
| Generator Over Current | 100%** | × | — | × | × |
| Negative Phase Sequence | 8% (1h) | — | × | — | × |
| Generator Power | 105%*** | — | × | — | × |
| Fail to Start | 80sec | × | — | × | × |
| Emergency Stop | — | × | — | × | × |
| Oil Pressure Low First | 400kPa | — | × | — | × |
| Oil Pressure Low Second | 150kPa | × | — | × | × |
| Coolant Temperature High First | 95°C | — | × | — | × |
| Coolant Temperature High Second | 101°C | × | — | × | × |
| Oil Temperature High ⁷ | 110°C | × | — | × | × |
| Exhaust Gas Temperature high ⁷ | 550°C | × | — | × | × |
| Winding Temperature High (U,V,W) ⁷ | 170°C* | — | × | — | × |
| Bearing Temperature High ⁷ | 80°C | — | × | — | × |
| Engine Over Speed First | 110% | — | × | — | × |
| Engine Over Speed Second | 115% | × | — | × | × |
| Engine Under Speed First | 80% | — | × | — | × |
| Engine Under Speed Second | 60% | × | — | × | × |
| Generator Over Frequency | 110% | — | × | — | × |
| Generator Under Frequency | 85% | — | × | — | × |
| Generator Over Voltage First | 115% | — | × | — | × |
| Generator Over Voltage Second | 130% | × | — | × | × |
| Generator Under Voltage First | 80% | — | × | — | × |
| Generator Under Voltage Second | 70% | × | — | × | × |
| Oil pressure Sensor Open Circuit | — | × | — | × | × |
| Loss of Magnetic Pickup Signal | — | × | — | × | × |
| L.O. Filter Clogged | 0.15MPa | — | × | — | × |
| Electrical Trip ³ | — | × | — | × | × |

- NOTE :
1. “×” marks are applicable items.
 2. “—” marks are not applicable items.
 3. Eng stop by Electrical trip signal will be done after Eng cooled.
 4. Regarding * , in case of “Prime” duty, that value is 150°C
 5. Regarding * * ,in case of “Prime” duty that value is 110%
 6. Regarding * * * ,in case of “Prime” duty that value is 115%.
 7. Optional items installed upon request.

4.4 Auxiliary input signals

If the functions as follows are necessary, please input external command signals to the control panel.

- (1) Remote start/stop
- (2) Electrical trip
- (3) CB close status (Generator closed auxiliary)

4.5 Status indicator

- (1) Remote start present
- (2) Generator ready
- (3) LO filter clogged
- (4) Electrical trip

4.6 Auxiliary output signals

These signals are output from control panel as 24V DC .

- (1) COMMON Shutdown alarm signal (for CB Trip)
 - (2) kW Overload alarm
 - (3) Low speed detection
 - (4) CB close command (pulse)
 - (5) CB open command (pulse)
 - (6) AUTO Mode
 - (7) Common Electrical Trip ※
 - (8) Energize to stop ※
 - (9) Common warning ※
 - (10) Failed to start alarm ※
 - (11) Over speed shutdown ※
 - (12) Emergency stop ※
 - (13) Low oil pressure ※
 - (14) High water temperature ※
- ※ Require optional 2157 relay unit

4.7 Operation

Generator control panel has three positions of key switch.

Each position is written in below.

- STOP / RESET : Engine stop and controller reset operation are available.

- ACTIVE : Auto and manual mode can be selected by auto and manual button on controller.

- PANEL LOCK : Even if auto or manual button is pushed, mode selection is not applicable.

Engine start and stop shall be done by operator. When engine trouble occurred engine should be stopped by generator panel automatically.

Remote start and stop control are available, when auto mode is selected by auto mode button.

5. LIMITING REQUIREMENT FOR FUEL OIL, COOLANT AND LUBRICATION OIL

5.1 Fuel system

Fuel to meet ASTM D975 grade No.2-D or BS2869 class A or JIS K-2204.

(APPENDIX-1)

Fuel tank and fuel pipes to be free of dirt, water or other foreign substances.

5.2 Cooling system

Coolant to meet the coolant specifications. (APPENDIX-2)

5.3 Lubrication system

Engine oil to meet API service classification CD or CF. (APPENDIX-3)

Do not use CE and CF-4 lube oils for Mitsubishi high-speed diesel engines.

- End of Specification -

APPENDIX-1**Limiting Requirements for Mitsubishi Diesel Fuel oils**

| Property | Limit | Remarks |
|---|--|-----------------------------|
| Flash point | 50°C,min. | |
| Distillation temperature, 90% point | 380°C,max. | |
| Pour point | 6°C,min. below the lowest atmospheric temperature | |
| Cloud point | Below the lowest atmospheric temperature | |
| Carbon residue on 10% residuum | 1.0% by weight, max. | |
| Cetane number | 45, min. | |
| Kinematic viscosity | 2.0 x 10 ⁻⁶ m ² /s, min.(30°C) 8.0 x 10 ⁻⁶ m ² /s, max.(50°C) 10.5 x 10 ⁻⁶ m ² /s, max.(40°C) 16.0 x 10 ⁻⁶ m ² /s, max.(30°C) | |
| Sulfur | 0.5% by weight, max. | |
| Water and sediment | 0.1% by volume, max. | |
| Ash | 0.03% by weight, max. | |
| Copper strip corrosion at 100°C,3hrs | No.3, max. | ASTM No.3 JIS K2531 No.3 |
| Gravity, 15/4°C | 0.80 to 0.87 | Reference |

ASTM D975-1992 diesel fuel oil No.2 - D or BS2869-1970 engine fuels class A and JIS K-2204-1988 gas oil type 2 or type 3 is appropriate.

APPENDIX-2**Coolant Specifications**

| Item | Chemical symbol | Unit | Recommend limit | Main malign effect | |
|--------------------------------|-------------------------------|------------|-----------------|--------------------|-----------------|
| | | | | Corrosion and rust | Scale formation |
| pH(25°C) | -- | -- | 6.5 to 8.5 | ○ | ○ |
| Electrical conductivity (25°C) | -- | $\mu S/cm$ | <400 | ○ | ○ |
| Total hardness | CaCO ₃ | ppm | <100 | -- | ○ |
| M alkalinity | CaCO ₃ | ppm | <150 | -- | ○ |
| Chlorine ion | Cl ⁻ | ppm | <100 | ○ | -- |
| Sulfuric acid ion | SO ₄ ²⁻ | ppm | <100 | ○ | -- |
| Total iron | Fe | ppm | <1.0 | -- | ○ |
| Silica | SiO ₂ | ppm | <50 | -- | ○ |
| Residue from evaporation | -- | ppm | <400 | -- | ○ |

This specification indicates the limitation for the new water.

Never use raw water alone as coolant water treatment with rust inhibitor or ethylene glycol base antifreeze is required.(Antifreeze is preferred.)

Maintain the antifreeze concentration more than 30% against corrosion.

APPENDIX-3**Recommended Lubricating Oil**

| Manufacturer | Brand name |
|--------------|-----------------------------------|
| Nippon Oil | HD S-3 Engine oil |
| Caltex | DELO Gold or Silver |
| Cosmo | Cosmo Diesel CD 30 |
| Esso | Essolube D-3 |
| General | General Gemico Super S-3 |
| Idemitsu | Apolloil Diesel Motive Custom |
| Kygnus | Mighty oil S-3 |
| Kyodo | Kyoseki Delmate D |
| Mobil | Mobil Delvac 1300 series |
| Showa-Shell | Shell Rimula X White Parrot Super |

- Remark : 1) When using those listed above, they should be confirmed as API service classification "CD", "CF". Some countries have them as "CF-4" and other. In care of that, please do not use them.
- 2) When using other oils than those listed above, they should be in API service classification "CD", "CF" and meet the requirements of MIL-L-2104C.
- 3) Do not use CE and CF-4 lube oils for Mitsubishi high-speed diesel engines.